

2008 Consumer Confidence Report

Water System Name: MD-6, Lake Shore Park

Report Date: 6/5/09

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2008.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Two wells drawing from deposits in fractured rock.

Name & location of source(s): The wells, known as 1 & 2, are located within the Lake Shore Maintenance District

Drinking Water Source Assessment information: A source water assessment was conducted for the Lake Shore wells in July 2002. While few contaminating activities were noted due to the remote location of the wells, the assessment identified other wells in the area as having the potential for outside contamination. Your system is already subject to a quarterly "DO NOT DRINK ADVISORY" due to the presence of naturally occurring contaminants. A copy of the complete assessment may be viewed at the Madera County Environmental Health Department, by visiting the State's website, www.dhs.ca.gov/ps/ddwem/technicaldwp/source_info/source_inde.htm, or by requesting a summary of the assessment from Environmental Health at (550) 675-7823.

Time and place of regularly scheduled board meetings for public participation: Meetings are held at 9:00 a.m. each Tuesday, except the fifth Tuesday of any month, at the Board of Supervisors Chambers: 200 w 4th Street, Madera.
Visit the County website, www.madera-county.com/supervisors/agenda/html for a copy of the agenda.

For more information, contact: Julio Padilla

Phone: (559) 675-7817

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (to be completed only if there was a detection of bacteria)	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a Mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the Year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb) – 2008	5	<5	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	5	0.12	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	12/08	37.70	14 – 56.1	none	none	Generally found in ground & surface water
Hardness (ppm)	12/08	122.77	28.3 - 172	none	none	Generally found in ground & surface water

*Any violation of an MCL or AL is marked with an asterisk. Additional information regarding the violation is provided later in this report.

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Gross Alpha (pCi/L)	3, 5, 8 & 11/07	95.4*	32.5 - 222	15	(0)	Erosion of natural deposits
Combined Radium 226 & 228 (pCi/L)	3, 5 & 9/07	2.49	2.39–2.64	5	(0)	Erosion of natural deposits
Uranium (pCi/L)	3, 5, 8 & 11/07	119.5*	41.1 – 244	20	.43	Erosion of natural deposits
Arsenic (ppb)	12/08	59.8*	<2 – 101	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Fluoride (ppm)	10/08	0.63	0 – 0.9	2.0	1	Erosion from natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Chromium (ppb)	12/08	6.50	1.2 – 16.5	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	12/08	42.2	3.6 – 63.9	500	N/A	Runoff/leaching from natural deposits; seawater influence
Color (units)	12/08	13.3	<5 - 25	15	N/A	Naturally-occurring organic materials
Iron (ppb)	12/08	586*	<100 – 1000	300	N/A	Leaching from natural deposits; industrial wastes
Manganese (ppb)	10/08	85.7*	0 – 130	50	N/A	Leaching from natural deposits
Specific Conductance (micromhos)	5 & 12/08	376.7	110 – 550	1600	N/A	Substances that form ions when in water; seawater influence
Sulfate (ppm)	12/08	6.7	0.55 – 9.9	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	10/08	47.7	7 – 120	1000	N/A	Runoff/leaching from natural deposits
Turbidity (Units)	12/08	5.7	0.3 – 10	5	N/A	Soil runoff
Odor (Units)	10/08	0.5	0 – 1.4	3	N/A	Naturally-occurring organic materials
Zinc (ppm)	10/08	0.04	0 – 0.13	5	N/A	Runoff/leaching from natural deposits; industrial wastes

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a Violation of Any Treatment Technique or Monitoring and Reporting Requirement

The Lake Shore system continues to show violations of the MCL in three primary areas: arsenic, gross alpha and uranium. Please take note of the following information. ***Arsenic:** Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer. ***Gross Alpha Particle Activity:** Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer. ***Uranium:** Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer.

In addition to the primary violations noted above, there were secondary violations for iron and manganese. Iron was found at a level exceeding the MCL of 300 ppb, while Manganese exceeded the 50 ppb MCL. Secondary standards are set to protect you against unpleasant aesthetic effects (e.g., tubs and sinks), and clothing while washing. The high levels are due to leaching of natural deposits. Violation of secondary MCLs do not pose a risk to public health and communities may choose whether or not to treat for them.

Our testing revealed violations in three primary areas and two violations of a secondary MCL. The source water for this system has consistently contained levels of gross alpha, uranium and arsenic higher than the EPA's MCL. Long-term exposure to contaminants in concentrations above the MCL has been determined by the EPA to lead to a higher incidence of cancer. **WE DO NOT RECOMMEND THAT YOU DRINK WATER FROM THIS SYSTEM.**

In May, this district was notified the approval of the Safe Drinking Water State Revolving Fund Application that was submitted in 2008 to solve the water quality issues for this community. As further details become available, additional communications and community meetings will occur. Community participation is important as improvement plans, available options, and associated rates will be discussed. We expect this process to begin this fall.

We hope you find this report informative and helpful. Please call our office if you have questions. The County of Madera works continually to provide the best available water to every tap. We ask that you, our customers, help us protect our water sources. Water is the heart of our community, our way of life, and our future.